GOVT. OF ASSAM OFFICE OF THE DIRECTOR, FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



SEE RULE - 18(2) NO. FRESTPW/ S | 350) 696 22-

Dated Guwahati the 3 2 22

The Principal, For College of Teacher Education, Mangaldai, Dist:- Darrang, Assam.

Men !

RENEWAL OF NO OBJECTION CERTIFICATE IN RESPECT OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE COLLEGE OF TEACHER EDUCATION LOCATED AT MANGALDAI, DIST:- DARRANG, ASSAM.

With reference to your completion report under No. Nil Dated 12.01.2022 and on the basis of the Inspection Report submitted by Sr. Station Officer, Pradeep Boro, I hereby certify that the building as per description below at Dag No. 1093, 1094 Patta No. - Mouza Chapai, (Place-Mangaldai, Darrang) has been inspected in respect of implementation of inbuilt Fire Fighting/ Fire Prevention/ Escape means measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No Objection in its occupation /utilization for the purpose of COLLEGE subject to conditions mentioned below.

DETAILS OF APPROVED OCCUPATION:-GROUND FLOOR: - (Assam type) 1. Floor area: - 883.20 m²

2. Purpose of utilization: - For College Purpose.

Details of inbuilt Fire Fighting and Fire Prevention measures:

Manually Operated Electric Fire Alarm system

2. Fire Extinguishers-8 Nos.

S.P. cum F&ES Advis P. Cum F. & E.S.A. for and on beat a Emergency Services, Assam Director of Fire and Emergency Parketes.

Assam, Guwahut Dated Guwahati the

NO. F&ES/FPW/ Copy to:-

1. The Deputy Commissioner. Darrang, Assam for information.

2. The Superintendent of Police, Darrang, Assam for information.

3. The Commissioner/ Chairman, Mangaldai Municipal Board, Assam for information.

4. The Sr. Station Officer, Mangaldai F&ES Station, for information and necessary action.

S.P. cum F&ES Adviser, for and on behalf of Director of Fire and Emergency Services, Assam, Guwahati.

CONDITIONS:-

1. The N.O.C. is valid up to: - 31.03.2023

2. There should not be any change of Trade for which this License has been issued.

3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.

4. The Fire Fighting equipments should be in serviceable condition at all time.

5. Water reservoir should always be kept full up to brim.

6. The entrance and exit and the water reservoir should always be free from any obstruction/

7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.

S.P. cum F&ES Adviser, S.P. Cum F & E.S.A. for and on behalf of Energency Services, Assam Director of Fire and Emery Francisco, Guwahati-1